
Plan Review Summary

Building Information

Project Name:	Cherry Emerson Generator Addition	Floor/Room #:	Exterior Mounted Generator
Building #:	B066	Department:	Design and Construction
Occupancy Type:	Business	Budget:	\$185,000
Construction Type:	IIIB	Type of Review:	Construction

Project Management

Project Manager:	Tony Gonzalez
Architect/Engineer of Record:	Dennis G. Carter, PE
Construction Manager:	
Aim Project Number:	0205-2020

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	11/10/2020
Disposition:	Approved	Date Completed:	11/16/2020

Status Statement

Note: New generator

Review Comments:

1. Approved

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2020-CP-298
-