

---

## Plan Review Summary

---

### Building Information

Project Name:	Boggs-AHU Replacement-Phase 1 Crane Plan 3	Floor/Room #:	
Building #:	103	Department:	Facilities-Design and Construction
Occupancy Type:	Business	Budget:	
Construction Type:	IIIA	Type of Review:	Logistics-Crane Plan

---

### Project Management

Project Manager:	Greg Spiro
Architect/Engineer of Record:	Johnson Spellman Associates
Construction Manager:	Jennifer Disotell
Aim Project Number:	0184-2019

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	11/24/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	11/30/2020

---

### Status Statement

Note: Crane plan

### Review Comments:

1. No cars in no fly zone
2. Safety person on site while crane in use

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

### Permits Issued:

1. Crane Plan Letter: 2020-CPL-308
-