

---

## Plan Review Summary

---

### Building Information

Project Name:	Veteran's Resource Center-Quad Café	Floor/Room #:	Top Floor
Building #:	167A	Department:	Student Life
Occupancy Type:	Business	Budget:	\$1500
Construction Type:	IIIB	Type of Review:	Demolition-REVISION

---

### Project Management

Project Manager:	Thomas Schneider
Architect/Engineer of Record:	Kara Thomas
Construction Manager:	
Aim Project Number:	0157-2020

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	3/5/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	3/10/2020

---

### Status Statement

Note: Demo of walls

### Review Comments:

1. Dumpster location must be approved
2. Care to maintain fire alarm and sprinkler integrity

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler
3. 100% Construction, Certificate of Occupancy (all work complete, close-out documents, etc.)

### Permits Issued:

1. Demolition: 2020-DP-059
-