
Plan Review Summary

Building Information

Project Name:	CODA Backfill-C21U, CEISMC and EXCEL	Floor/Room #:	All
Building #:	155,155B	Department:	CPSM
Occupancy Type:	Business	Budget:	\$1M, \$900K, \$1M
Construction Type:	IIB	Type of Review:	Construction/Demolition

Project Management

Project Manager:	Carla Barbour
Architect/Engineer of Record:	ASD/SKY
Construction Manager:	Carla Barbour
Aim Project Number:	0100-2020; 0286-2020; 0334-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/12/2020
Disposition:	Approved	Date Completed:	3/19/2020

Status Statement

Note: Demolition Permit Only

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

Permits Issued:

1. Demolition: 2020-DP-064
-