
Plan Review Summary

Building Information

Project Name:	Russ Chandler Baseball Renovation	Floor/Room #:	
Building #:	168	Department:	GT Design and Construction
Occupancy Type:	Business	Budget:	\$10M
Construction Type:	IIIB	Type of Review:	Logistics-Dumpster Location

Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	Cheung-Li Wang
Construction Manager:	Jackie Avello
Aim Project Number:	2020-0359

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/3/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	6/4/2020

Status Statement

Note: Dumpster plan

Review Comments:

1. Dumpster location approved
2. Road behind baseball is a dedicated FIRE LANE and cannot be blocked by fencing
3. Dumpster permit good for 60 days

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Dumpster Permit – 2020-DPL-144
-