
Plan Review Summary

Building Information

Project Name:	Brock Practice Facility Fire Alarm Renovation	Floor/Room #:	
Building #:	200	Department:	Athletics
Occupancy Type:	Other	Budget:	\$21,000.00
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Angela Williams
Architect/Engineer of Record:	
Construction Manager:	Angela Williams
Aim Project Number:	

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	1/6/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	1/7/2020

Status Statement

Note: Panel for Panel swap

Review Comments:

1. Approved with cellular dialer

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm 2020-FA-007
-