

Plan Review Summary

Building Information

Project Name:	Tech Way-Fire Alarm Upgrade MRR FY19	Floor/Room #:	All Floors
Building #:	136	Department:	GT Fire & Life Safety Office
Occupancy Type:	Business	Budget:	\$500,000
Construction Type:	IIIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Cristina Fannin
Architect/Engineer of Record:	EMC Security/Gene Musco
Construction Manager:	Cristina Fannin
Aim Project Number:	0365-2019

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	1/14/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	2/10/2020

Status Statement

Note: Fire alarm upgrade

Review Comments:

1. Must tie into Onyx workstation and graphics

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm 2020-FA-016