
Plan Review Summary

Building Information

Project Name:	Lyman Hall Fire Alarm System Upgrade MRR2020	Floor/Room #:	All Floors
Building #:	029A	Department:	Environmental Health and Safety
Occupancy Type:	Business	Budget:	\$350,000
Construction Type:	IVB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Brian Clarke
Architect/Engineer of Record:	Dennis Carter/Concord Project Consulting, Inc.
Construction Manager:	Cristina Fannin
Aim Project Number:	0078-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/4/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	3/6/2020

Review Comments:

1. Manufacturer specifications for Open-area imaging detection was submitted. An atrium is indicated on the third floor plan.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm: 2020-FA-054
-