

---

## Plan Review Summary

---

### Building Information

Project Name:	MRR FY19 Fire Alarm System Upgrades-Cherry Emerson	Floor/Room #:	All Floors
Building #:	066	Department:	EHS
Occupancy Type:	Business	Budget:	\$500,000
Construction Type:	IIB	Type of Review:	AS-Builts

---

### Project Management

Project Manager:	Cristina Fannin
Architect/Engineer of Record:	EMC Security/Devin Clarke
Construction Manager:	Cristina Fannin
Aim Project Number:	0365-2019

---

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/12/2020
Disposition:	Approved	Date Completed:	4/6/2020

---

#### **General Note:**

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

#### **Additional Requirements (as needed):**

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

#### **Plan / Shop Drawings Required:**

1. Fire Suppression
2. Fire Alarm

#### **Inspections Required:**

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

#### **Permits Issued:**

1. Fire Alarm: 2020-FA-066
-