
Plan Review Summary

Building Information

Project Name:	Campus Center Phase 1 Fire Alarm REVISION	Floor/Room #:	
Building #:	215, 216, 217	Department:	Facilities-Design and Construction
Occupancy Type:	Business	Budget:	
Construction Type:	IIB	Type of Review:	Fire Alarm-REVISION

Project Management

Project Manager:	JohnDuConge
Architect/Engineer of Record:	Cooper Carry
Construction Manager:	Gilbane Building Company
Aim Project Number:	BOR-PPV-30-1801

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/25/2020
Disposition:	Approved	Date Completed:	3/31/2020

Status Statement

Note: All Buildings; Fire Alarm Systems

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued: 2020-FA-080
