
Plan Review Summary

Building Information

Project Name:	GTRI CCRF Building B10 Renovation-Fire Alarm	Floor/Room #:	1
Building #:	761	Department:	GTRI
Occupancy Type:	Business	Budget:	971,000
Construction Type:	IIB	Type of Review:	Fire Alarm-REVISION

Project Management

Project Manager:	Nic Palfrey
Architect/Engineer of Record:	Concord Engineering-Dennis Carter
Construction Manager:	McCarthy-Dan Hesse
Aim Project Number:	0153-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/25/2020
Disposition:	Approved	Date Completed:	3/26/2020

Status Statement

Note: Fire Alarm Revision

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

Permits Issued:

1. Fire Alarm 2020-CP-081
-