
Plan Review Summary

Building Information

Project Name:	Boggs-Lab Renovation for Tianye Niu	Floor/Room #:	3rd Floor
Building #:	103	Department:	Engineering
Occupancy Type:	Business	Budget:	\$5000
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Thomas Schneider
Architect/Engineer of Record:	Bill Oswell
Construction Manager:	
Aim Project Number:	0027-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	4/13/2020
Disposition:	Approved	Date Completed:	4/22/2020

Status Statement

Note: 1 Power Supply panel; 2 horn/strobes

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm: 2020-FA-100
-