
Plan Review Summary

Building Information

Project Name:	Veteran's Resource Center-Quad Cafe	Floor/Room #:	Top Floor
Building #:	167A	Department:	Student Life
Occupancy Type:	Business	Budget:	\$400,000.00
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Thomas Schneider
Architect/Engineer of Record:	Kara Thomas
Construction Manager:	Jonathan Byers
Aim Project Number:	0157-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	5/28/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	6/9/2020

Status Statement

Note: Addition of Fire Alarm Devices; 1 power supply, 7 smoke detectors, 3 pull stations, 2 wall horn/strobes, 3 ceiling horn/strobes, 1 wall strobe

Review Comments:

1. Horn/strobes and strobe shall be white in color

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm: 2020-FA-142
-