

---

## Plan Review Summary

---

### Building Information

Project Name:	GPB-4th Floor Open Office Expansion	Floor/Room #:	4th Floor
Building #:	141A	Department:	GTRI
Occupancy Type:	Business	Budget:	\$9,800
Construction Type:	IIIB	Type of Review:	Fire Alarm

---

### Project Management

Project Manager:	Andrew Sharp
Architect/Engineer of Record:	Concord Project Consulting
Construction Manager:	Andrew Sharp
Aim Project Number:	0407-2019

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/12/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	6/19/2020

---

### Status Statement

Note: New devices and relocating devices for office expansion

### Review Comments:

1. Approved
2. Note\* Campus standard on strobe bases are normally white, however red will be permitted this job

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Alarm

### Permits Issued:

1. Fire Alarm: 2020-FA-160
-