

---

## Plan Review Summary

---

### Building Information

---

Project Name:	Campus Center-Exhibition Hall-Fire Alarm-AS-BUILTS REVISION	Floor/Room #:	Entire Building
Building #:	217	Department:	Facilities-Design and Construction
Occupancy Type:	Assembly	Budget:	
Construction Type:	IIIB	Type of Review:	Fire Alarm As-Builts

---

### Project Management

---

Project Manager:	John DuConge
Architect/Engineer of Record:	Cooper Carry
Construction Manager:	Gilbane Construction
Aim Project Number:	BOR-PPV-30-1801

---

### Reviewer Information

---

Reviewer Name:	Jerry Marrison	Date Received:	6/18/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	6/19/2020

---

### Status Statement

Note: Fire alarm As Builts for exhibition hall

### Review Comments:

1. Approved plans accepted
2. Clear for commissioning after 3 devices replaced

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Alarm: 2020-FA-174
-