
Plan Review Summary

Building Information

Project Name:	Savant 3rd Floor Graduate Studies Optimization	Floor/Room #:	3rd Floor
Building #:	038	Department:	Office of Graduate Studies
Occupancy Type:	Business	Budget:	\$382,000.00
Construction Type:	IIIA	Type of Review:	Fire Alarm

Project Management

Project Manager:	
Architect/Engineer of Record:	Maria Del Mar Ceballos
Construction Manager:	Mitchell Shelton
Aim Project Number:	0134-2019

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/18/2020
Disposition:	Approved	Date Completed:	6/29/2020

Status Statement

Note: Relocation of 4 devices and adjusting candela

Review Comments:

1. Approved as submitted

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

ns Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm: 2020-FA-176
-