
Plan Review Summary

Building Information

Project Name:	Hefner Residence Hall Fire Alarm Replacement AS-BUILTS	Floor/Room #:	
Building #:	107	Department:	GT Housing
Occupancy Type:	Dormitory	Budget:	\$300,000
Construction Type:	IIIB	Type of Review:	Fire Alarm- AS BUILTS

Project Management

Project Manager:	Spencer Sheffield
Architect/Engineer of Record:	Fisher Engineering
Construction Manager:	Spencer Sheffield
Aim Project Number:	0245-2020

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/23/2020
Disposition:	Approved	Date Completed:	6/29/2020

Status Statement

Note: Fire alarm panel replacement project

Review Comments:

1. Approved for 100% and commissioning

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Inspections Required:

1. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm: 2020-FA-180
-