
Plan Review Summary

Building Information

Project Name:	A French Office Renovation	Floor/Room #:	104A and 105
Building #:	030	Department:	Provost and EVP Academic Affairs
Occupancy Type:	Business	Budget:	\$44,000
Construction Type:	IIIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Allison Gerstung
Architect/Engineer of Record:	Tony Gonzalez
Construction Manager:	Allison Gerstung
Aim Project Number:	0207-2020

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	7/1/2020
Disposition:	Approved	Date Completed:	7/6/2020

Status Statement

Note: Relocated and adding devices to accommodate new wall

Review Comments:

1. Approved

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm: 2020-FA-187
-