

---

## Plan Review Summary

---

### Building Information

Project Name:	Holland Plant Gender Neutral Restrooms	Floor/Room #:	Basement
Building #:	026	Department:	Facilities
Occupancy Type:	Business	Budget:	\$120,000
Construction Type:	IIIB	Type of Review:	Fire Alarm

---

### Project Management

Project Manager:	Amber Chellis-Omedo
Architect/Engineer of Record:	Tanya Richard (Corgan)
Construction Manager:	Fenella Bryant
Aim Project Number:	0370-2019

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	7/15/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	7/20/2020

---

### Status Statement

Note: 2 new strobes in restroom

### Review Comments:

1. Devices shall be white per yellowbook standard

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Alarm: 2020-FA-206
-