
Plan Review Summary

Building Information

Project Name:	Women's Basketball Locker Room Fire Alarm-REVISION	Floor/Room #:	FA, Full Building
Building #:	73A	Department:	Design and Construction
Occupancy Type:	Business	Budget:	\$650,000
Construction Type:	IIIB	Type of Review:	Fire Alarm-Revision

Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	Jim Winer
Construction Manager:	Brian Oliver-DPR
Aim Project Number:	2019-0312

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	7/29/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	8/10/2020

Status Statement

Note: Upgraded fire alarm panel and devices

Review Comments:

1. All alarm testing and pretesting must notify occupants with 24 hours of testing. Signage must be picked up from the Fire Safety Office on the 48 hours before testing actually occurs.
2. Commissioning of the alarm system will require as-builts to be submitted with alarm points from the central station monitoring company

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm: 2020-FA-223
-