
Plan Review Summary

Building Information

Project Name:	Renovation of Petit IBB Wing 1D	Floor/Room #:	1st Floor-Partial
Building #:	146	Department:	CoE
Occupancy Type:	Business	Budget:	\$248,000
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Bill Oswell
Architect/Engineer of Record:	Kyle Epstein(Epstein & Associates)
Construction Manager:	Fenella Bryant
Aim Project Number:	0003-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	8/5/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	8/7/2020

Status Statement

Note: New Fire Alarm Devices: smoke detectors and horn/strobes

Review Comments:

1. Fire Alarm Devices shall be White in color

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm: 2020-FA-231
-