
Plan Review Summary

Building Information

Project Name:	Kitchen Hood Fire Suppression-Fire Alarm Panel Interconnection	Floor/Room #:	Multiple Housing Residence Halls
Building #:	Multiple Housing Residence Halls	Department:	Housing
Occupancy Type:	Dormitory	Budget:	\$468,802.00
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Daniel Powell
Architect/Engineer of Record:	
Construction Manager:	
Aim Project Number:	0174-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	9/15/2020
Disposition:	Approved	Date Completed:	9/16/2020

Status Statement

Note: Fire Alarm Monitor module installation for Hood Suppression Systems in multiple housing buildings

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System
2. Fire Alarm

Permits Issued:

1. Fire Alarm: 2020-FA-250