
Plan Review Summary

Building Information

Project Name:	B12 GTRI South Campus-ELSYS Lab	Floor/Room #:	1210-1290
Building #:	763	Department:	Georgia Tech Research Institute
Occupancy Type:	Business	Budget:	\$13,495
Construction Type:	IIIA	Type of Review:	Fire Alarm

Project Management

Project Manager:	Nicolas Palfrey
Architect/Engineer of Record:	Christopher Atwell
Construction Manager:	Nicolas Palfrey
Aim Project Number:	0212-2020

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	10/15/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	10/19/2020

Status Statement

Note: NAC added new devices added

Review Comments:

1. Confirm strobes are white per Yellow Book Standard

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm: 2020-FA-287
-