
Plan Review Summary

Building Information

Project Name:	Fire Alarm Panel Replacement-Guggenheim	Floor/Room #:	
Building #:	040	Department:	Facilities U&E
Occupancy Type:	Business	Budget:	\$16,020
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Jennifer Disotell
Architect/Engineer of Record:	Johnson Controls-David McLean
Construction Manager:	Jennifer Disotell
Aim Project Number:	0901-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	11/5/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	11/13/2020

Status Statement

Note: Fire Alarm Panel Replacement; Simplex 4100 series

Review Comments:

1. The new fire alarm panel shall be compatible with all existing devices.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm: 2020-FA-299
-