

## Plan Review Summary

### Building Information

Project Name:	Campus Center-Pavilion	Floor/Room #:	All
Building #:	216	Department:	Facilities Design & Construction
Occupancy Type:	Business	Budget:	\$90M
Construction Type:	IIB	Type of Review:	Fire Suppression

### Project Management

Project Manager:	John DuConge
Architect/Engineer of Record:	Christopher Bivins(Cooper Carry)
Construction Manager:	Christian Lee (Gilbane)
Aim Project Number:	BOR-PPV-30-1801

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	1/9/2020
Disposition:	Approved	Date Completed:	2/4/2020

### Status Statement

Note: Pavilion; 2 buildings

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)
- 3.

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Thrust Block Inspections
3. Underground Pressure Test
4. System Flush
5. Sprinkler Pipe Inspections
6. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
7. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Suppression System: 2020-FS-015