

---

## Plan Review Summary

---

### Building Information

Project Name:	Campus Services Warehouse CO Work	Floor/Room #:	Suites 100 & 200
Building #:	882	Department:	Housing
Occupancy Type:	Other	Budget:	\$137,225.00
Construction Type:	IIIB	Type of Review:	Fire Suppression-REVISION

---

### Project Management

Project Manager:	Daniel Powell
Architect/Engineer of Record:	Lee Welsh
Construction Manager:	
Aim Project Number:	0207-2019

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	2/7/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	2/13/2020

---

### Status Statement

Note: Sprinkler Work

### Review Comments:

1. Must have approved "FDC" sign posted
2. Locking FDC caps from Knox are required
3. Hydraulic calculation plate must be etched

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)
1. Red Book Completion and Fixed Location Designation

### Plan / Shop Drawings Required:

1. Fire Suppression

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Sprinkler Pipe Inspections
3. Rough-in
4. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
5. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
6. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)
1. Fire Alarm

### Permits Issued:

1. Fire Suppression System 2020-FS-033
-