
Plan Review Summary

Building Information

Project Name:	Cherry Emerson Brown/Diggle Lab	Floor/Room #:	1st and 3rd Floor(partial)
Building #:	66A	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$630,000
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Geoffery Maulion(FLAD)
Construction Manager:	Fenella Bryant
Aim Project Number:	0336-2019

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/12/2020
Disposition:	Approved	Date Completed:	3/18/2020

Status Statement

Note: Pre-engineered Dry Chemical Fixed Nozzles System; 4 systems

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System
2. Fire Alarm

Permits Issued:

1. Fire Suppression System: 2020-FS-065
-