

## Plan Review Summary

### Building Information

Project Name:	Campus Services Warehouse CO Work	Floor/Room #:	Suites 100 & 200
Building #:	882	Department:	Housing
Occupancy Type:	Business	Budget:	\$137,225.00
Construction Type:	IIB	Type of Review:	Fire Suppression

### Project Management

Project Manager:	Daniel Powell
Architect/Engineer of Record:	Jeffrey Juliano
Construction Manager:	
Aim Project Number:	1814-7917

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/13/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	3/19/2020

### Status Statement

Note: Light Hazard Design; Fire Sprinkler System 1<sup>st</sup> floor and 2 floor offices

### Review Comments:

1. Manufacturer specifications for standard response upright and pendant fire sprinkler heads were submitted, however, the plans indicate quick response fire sprinkler heads. Please have manufacturer specifications for the quick response heads on site if reference is needed during inspections.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Sprinkler Pipe Inspections
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

**Permits Issued:**

1. Fire Suppression System:

2020-FS-072

---

