

Plan Review Summary

Building Information

Project Name:	Dry Pipe Replacement-Bobby Dodd Upper West	Floor/Room #:	Upper West Stands
Building #:	031	Department:	Facilities-O&M
Occupancy Type:	Business	Budget:	\$35,235
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:
Architect/Engineer of Record: Alliance Fire Protection Services, Inc.
Construction Manager: Jennifer Disotell
Aim Project Number:

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/19/2020
Disposition:	Approved	Date Completed:	3/23/2020

Status Statement

Note: Ordinary Hazard I and Light Hazard fire sprinkler systems for concessions and restrooms; Dry Systems

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

Permits Issued:

1. Fire Suppression System: 2020-FS-077