

Plan Review Summary

Building Information

Project Name:	Curran Street Parking Deck Fire Sprinkler Replacement	Floor/Room #:	
Building #:	139	Department:	GT parking
Occupancy Type:	Other	Budget:	
Construction Type:	IIB	Type of Review:	Fire Suppression-Consultation

Project Management

Project Manager:	Spencer Sheffield
Architect/Engineer of Record:	Fisher Engineering
Construction Manager:	Spencer Sheffield
Aim Project Number:	0130-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/25/2020
Disposition:	Consultation Provided - Submittal Required Elsewhere	Date Completed:	4/1/2020

Status Statement

Note: Fire Sprinkler & Standpipe

Review Comments:

1. Hydraulic Calculations and manufacturer specifications will be required at submittal for permitting.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Thrust Block Inspections
3. Underground Pressure Test
4. System Flush
5. Sprinkler Pipe Inspections
6. Rough-in
7. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)

8. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
9. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System: 2020-FS-085
4. Fire Alarm

