

## Plan Review Summary

### Building Information

Project Name:	Biomedical Engineering Lab Renovation-TEP Fire Suppression	Floor/Room #:	Suite 200: Labs 224, 227 and 228; Office 214
Building #:	785 Tuff is the owner	Department:	Biomedical Engineering
Occupancy Type:	Business	Budget:	\$500,000
Construction Type:	IIB	Type of Review:	Fire Suppression

### Project Management

Project Manager:	Gary Fowler, Collaborative Real Estate
Architect/Engineer of Record:	Robert Eric O'Keefe, TVS Design
Construction Manager:	Darryell Weber-Weber Construction
Aim Project Number:	0066-2020

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	3/30/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	4/7/2020

### Status Statement

Note: Fire Sprinkler Addition/Relocations

### Review Comments:

1. The fire sprinkler system indicate design to Ordinary Hazard; fire sprinkler heads cannot be more than 7.5 feet off a wall.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Suppression System: 2020-FS-090