

## Plan Review Summary

### Building Information

Project Name:	Boggs-Lab Renovation for Tianye Niu	Floor/Room #:	Floor 3 Rooms 3-67 and 3-68
Building #:	103	Department:	College Of Engineering
Occupancy Type:	Business	Budget:	\$250,000.00
Construction Type:	IIB	Type of Review:	Fire Suppression

### Project Management

Project Manager:	Bill Oswell
Architect/Engineer of Record:	Bill Oswell
Construction Manager:	Thomas Schneider
Aim Project Number:	0027-2020

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	4/8/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	4/13/2020

### Status Statement

Note: Fire Sprinklers

### Review Comments:

1. Labs using chemicals shall be designed to ordinary hazard 2 for Class A and B; ordinary hazard 1 for Class C and D

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Suppression System: 2020-FS-093