

## Plan Review Summary

### Building Information

Project Name:	Women's Basketball Locker Room	Floor/Room #:	1st Floor, locker and lounge area
Building #:	73A	Department:	GT Design and Construction
Occupancy Type:	Business	Budget:	\$650,000
Construction Type:	IIIB	Type of Review:	Fire Suppression

### Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	Jim Winer
Construction Manager:	Brian Oliver-DPR
Aim Project Number:	2019-0312

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/12/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	6/18/2020

### Status Statement

Note: Addition of sprinklers and relocation of a few heads

### Review Comments:

1. Plan approved as submitted
2. Confirm correct number of extra sprinklers are present per code
3. Provide signage on sprinkler piping as required by code using the approved sign in GTFSSO website

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Sprinkler Pipe Inspections
3. Rough-in
4. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
5. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
6. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Suppression System
2. Fire Alarm

### Permits Issued:

1. Fire Suppression System: 2020-FS-162