Plan Review Summary

151 Sixth Street, Suite 341

Atlanta, Georgia 30332

404-894-FIRE (3473)

		Building Information	
Project Name:	Renovation of IBB Wing 1D	Floor/Room #:	1st Floor-Partial
Building #:	146	Department:	CoE
Occupancy Type:	Business	Budget:	\$450,000.00
Construction Type:	IIB	Type of Review:	Fire Suppression
		Project Management	
Project Manager:	Bill Oswell	SAFF7	
Architect/Engineer of	f Record: Kyle Epstein		
Construction Manage	er: Fenella Bryant		
Aim Project Number:	0003-2020		
		Reviewer Information	
Reviewer Name:	Jake LeJeune	Date Received:	6/17/2020
Disposition:	Approved	Date Completed:	6/24/2020
Status Statement	A PI H	- Fi	

Ge<u>orgi</u>a

Tech

Fire Safety

Note: Replace 57 heads with quick response; relocate 1 sprinkler head; add 2 new sprinkler heads

General Note:

- 1. Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request
- 2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Environmental Health & Safety

Inspections Required:

- 1. Fire Safety Office Project Kick-Off Meeting
- 2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
- 3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Suppression System: 2020-FS-168