

---

## Plan Review Summary

---

### Building Information

Project Name:	4th Floor Open Office Expansion-GPB	Floor/Room #:	4th Floor
Building #:	141A	Department:	GTRI
Occupancy Type:	Business	Budget:	\$11,500
Construction Type:	IIB	Type of Review:	Fire Suppression

---

### Project Management

Project Manager:	Andrew Sharp
Architect/Engineer of Record:	Concord Project Consulting
Construction Manager:	Andrew Sharp
Aim Project Number:	0407-2019

---

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	6/17/2020
Disposition:	Approved	Date Completed:	6/29/2020

---

### Status Statement

Note: Fire Sprinkler System; 72 fire sprinkler heads; addition/relocation

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Suppression System: 2020-FS-172
-