Plan Review Summary

Building Information			
Project Name:	Perry/Matheson Sprinkler Install	Floor/Room #:	Building Wide
Building #:	091	Department:	GT Housing Facilities
Occupancy Type:	Dormitory	Budget:	\$200,000
Construction Type:	IIIB	Type of Review:	Fire Suppression-REVISION
Project Management			
Project Manager:	Prakhar Sahu		
Architect/Engineer of	Record: Pro-Tec Fire		
Construction Manage	er: Matthew Alison		
Aim Project Number:	19-217006		
Reviewer Information			
Reviewer Name:	Jerry Marrison	Date Received:	6/29/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	7/6/2020

Status Statement

Note: Addition of sprinkler system off 4" standpipe system

Review Comments:

- 1. GT Standard Hydraulic calc plate shall be made of metal, information shall be etched into plate
- NFPA 13 Sprinkler control valves Signs are reflected shall be placed at each system control riser, antifreeze loop, and auxiliary system control valve, etc
- 3. NFPA 13 The installing contractor shall provide a general information sign used to determine system design basis and information relevant to the inspection, testing, and maintenance requirements required by NFPA 25
- 4. Flow sensor to be tied into fire alarm system
- 5. GT Standard FDC shall have Knox Locking FDC caps
- 6. Trim gauges and control valves at each level

General Note:

- 1. Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request
- 2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

- 1. Fire Suppression
- 2. Fire Alarm

Inspections Required:

- 1. Fire Safety Office Project Kick-Off Meeting
- 2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
- 3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
- 4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete,
- commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm



