
Plan Review Summary

Building Information

Project Name:	Hanson New Sprinkler System	Floor/Room #:	All
Building #:	093	Department:	GT Housing Facilities
Occupancy Type:	Dormitory	Budget:	\$100,000
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Prakhar Sahu
Architect/Engineer of Record:	Pro-Tec Fire
Construction Manager:	Matthew Alison
Aim Project Number:	

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/22/2020
Disposition:	Approved	Date Completed:	7/28/2020

Status Statement

Note: New NFPA 13R Fire Sprinkler System; tie into existing 4' standpipe system risers in stairwell

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Suppression System: 2020-FS-213
-