

---

## Plan Review Summary

---

### Building Information

Project Name:	McGuire Lab Renovation Fire Suppression	Floor/Room #:	2165
Building #:	147	Department:	Facilities-Design and Construction
Occupancy Type:	Business	Budget:	\$150,000
Construction Type:	IIB	Type of Review:	Fire Suppression

### Project Management

Project Manager:	Kynthia Gaines
Architect/Engineer of Record:	Kyle Epstein, Warren Epstein & Associates
Construction Manager:	Kynthia Gaines
Aim Project Number:	0137-2020

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/21/2020
Disposition:	Approved	Date Completed:	7/28/2020

### Status Statement

Note: Quick Response Fire Sprinkler installation; 6 heads

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Suppression System: 2020-FS-215
-