

---

## Plan Review Summary

---

### Building Information

Project Name:	Woodruff New Sprinkler System-REVISION	Floor/Room #:	All
Building #:	116	Department:	GT Housing Facilities
Occupancy Type:	Dormitory	Budget:	\$200,000
Construction Type:	IIB	Type of Review:	Fire Suppression-REVISION

---

### Project Management

Project Manager:	Prakhar Sahu
Architect/Engineer of Record:	Pro-Tec Fire
Construction Manager:	Matthew Alison
Aim Project Number:	

---

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/29/2020
Disposition:	Approved	Date Completed:	8/4/2020

---

### Status Statement

Note: New Fire Sprinkler System Installation; connect to existing 4 inch standpipe

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Suppression System: 2020-FS-221
-