

---

## Plan Review Summary

---

### Building Information

Project Name:	Kitchen Hood Fire Suppression	Floor/Room #:	Multiple Housing Residence Halls
Building #:	Multiple Housing Residence Halls	Department:	Housing
Occupancy Type:	Dormitory	Budget:	\$468,802.00
Construction Type:	IIIB	Type of Review:	Fire Suppression

---

### Project Management

Project Manager:	Daniel Powell
Architect/Engineer of Record:	
Construction Manager:	
Aim Project Number:	0174-2020

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	8/19/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	8/21/2020

---

### Status Statement

Note: Guardian Hood Suppression Systems

### Review Comments:

1. Must tie into fire alarm panel

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Alarm

### Permits Issued:

1. Fire Suppression System: 2020-FS-243
-