
Plan Review Summary

Building Information

Project Name:	ELSYS Laboratory	Floor/Room #:	1210-1290
Building #:	763	Department:	GTRI
Occupancy Type:	Business	Budget:	\$26,400
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Nicolas Palfrey
Architect/Engineer of Record:	Brad Johnson
Construction Manager:	Nicolas Palfrey
Aim Project Number:	0212-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	9/15/2020
Disposition:	Approved	Date Completed:	9/16/2020

Status Statement

Note: Add and relocate fire sprinkler heads

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System
2. Fire Alarm

Permits Issued:

1. Fire Suppression System: 2020-FS-252
-