

---

## Plan Review Summary

---

### Building Information

---

Project Name:	Reno of Instructional Space-Howey Physics Ancillary RISER-REVISION	Floor/Room #:	4 stairwells
Building #:	081	Department:	GT E, H & S
Occupancy Type:	Business	Budget:	\$165,00
Construction Type:	IIB	Type of Review:	Fire Suppression

---

### Project Management

---

Project Manager:	Nicolas Palfrey
Architect/Engineer of Record:	Joshua Britt
Construction Manager:	Nicolas Palfrey
Aim Project Number:	0096-2018

---

### Reviewer Information

---

Reviewer Name:	Jake LeJeune	Date Received:	9/29/2020
Disposition:	Approved	Date Completed:	10/16/2020

---

### Status Statement

Note: Standpipe System; 1000gpm @ 168psi

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Suppression System: 2020-FS-266
-