

---

## Plan Review Summary

---

### Building Information

Project Name:	Woodruff Hood Suppression Kits	Floor/Room #:	10 Community Kitchens
Building #:	116	Department:	GT Housing Facilities
Occupancy Type:	Dormitory	Budget:	\$53,000
Construction Type:	IIIA	Type of Review:	Fire Alarm

---

### Project Management

Project Manager:	John Witt
Architect/Engineer of Record:	
Construction Manager:	Mike Bowling
Aim Project Number:	

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	10/13/2020
Disposition:	Approved	Date Completed:	10/14/2020

---

### Status Statement

Note: Guardian Hood Suppression Systems

### Review Comments:

1. Approved

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Alarm

### Permits Issued:

1. Fire Suppression System: 2020-FS-285
-