

---

## Plan Review Summary

---

### Building Information

Project Name:	Cleanroom Bay 4 & 5 Novelis-Fire Sprinkler-Pettit	Floor/Room #:	Cleanroom Level-Lab 021& 028
Building #:	095	Department:	IEN
Occupancy Type:	Other	Budget:	\$19,000
Construction Type:	IIB	Type of Review:	Fire Suppression

---

### Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Alliance Fire Protection Services
Construction Manager:	Jennifer Disotell
Aim Project Number:	0042-2021

---

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	11/19/2020
Disposition:	Approved	Date Completed:	11/25/2020

---

### Status Statement

Note: Fire Sprinkler System Cleanroom Bays 4 and 5

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

### Permits Issued:

1. Fire Suppression System: 2020-FS-305
-