

---

## Plan Review Summary

---

### Building Information

Project Name:	Cherry Emerson Brown/Diggle Lab	Floor/Room #:	1st and 3rd Floor (partial)
Building #:	66A	Department:	College Of Sciences
Occupancy Type:	Business	Budget:	\$630,000.00
Construction Type:	IIIB	Type of Review:	Fire Suppression

---

### Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Geoffery Maulion(FLAD)
Construction Manager:	Fenella Bryant
Aim Project Number:	0336-2019

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	1/8/2020
Disposition:	Declined	Date Completed:	1/29/2020

---

### Status Statement

Note: Chemical Fire Suppression System

### Review Comments:

1. No Construction Type noted
2. No occupancy type noted
3. No True North indicator
4. Rooms not labeled
5. Not stamped and signed
6. No code summary

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Additional Requirements (as needed):

1. Fire Emergency Response Plans
  2. Red Book Completion and Fixed Location Designation
- 

2020-PR-014