

## Plan Review Summary

### Building Information

Project Name:	Campus Center Phase 1 Fire Alarm	Floor/Room #:	
Building #:	All Buildings	Department:	Design and Construction
Occupancy Type:	Business	Budget:	\$110M
Construction Type:	IA	Type of Review:	Fire Alarm

### Project Management

Project Manager:	John DuConge
Architect/Engineer of Record:	Cooper Carry
Construction Manager:	Gilbane Building Company
Aim Project Number:	BOR-PPV-30-1801

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	2/14/2020
Disposition:	Declined	Date Completed:	2/26/2020

### Status Statement

Note: Fire Alarm System Installation

### Review Comments:

1. Please provide a Strobe in Exhibition Hall Room 222 in accordance with NFPA 72.
2. Please provide a smoke detector in Exhibition Hall room 242A in accordance with GT Yellow book Standard.
3. Please provide a Smoke detector and heat detector in the pit and top of the elevator shaft of the Exhibition Hall accordingly.
4. There are Heat Detectors in all restrooms in all buildings instead of Smoke Detectors? The buildings are equipped with a monitored/supervised fire sprinkler system. Why are heat detectors being used?
5. Please provide a smoke detector in the Pavilion room 1104D Copier/Mail Rm and provide a smoke detector in the Pavilion room 1224D Storage.
6. Please provide a smoke detector in the fire sprinkler riser room in the Pavilion.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Alarm