
Plan Review Summary

Building Information

Project Name:	Lab Ventilation Controls Upgrade-Ford ES&T	Floor/Room #:	Entire Building
Building #:	147	Department:	Facilities Design & Construction
Occupancy Type:	Business	Budget:	\$6,400,000
Construction Type:	IIIB	Type of Review:	Construction

Project Management

Project Manager:	Kynthia Gaines
Architect/Engineer of Record:	Walker Jones, Newcomb and Boyd
Construction Manager:	Kynthia Gaines
Aim Project Number:	C378-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	2/20/2020
Disposition:	Declined	Date Completed:	2/26/2020

Status Statement

Note: Fire damper additions

Review Comments:

1. No Construction Type listed
2. No Occupancy Type
3. No Points of Reference Shown (North)
4. No Cut Sheets-Listed Equipment
5. No Code Summary

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
 2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work
-