

Plan Review Summary

Building Information

| | | | |
|--------------------|--|-----------------|-------------------------|
| Project Name: | Burdells Bookstore Relocation-Retail Fixture Layout ONLY | Floor/Room #: | |
| Building #: | 216 | Department: | Design and Construction |
| Occupancy Type: | Business | Budget: | \$40,000 |
| Construction Type: | IIB | Type of Review: | Construction |

Project Management

| | |
|-------------------------------|-------------------------------|
| Project Manager: | Brad Morris |
| Architect/Engineer of Record: | Scott Lasky, Lasky Architects |
| Construction Manager: | |
| Aim Project Number: | 0057-2020 |

Reviewer Information

| | | | |
|----------------|--------------|-----------------|-----------|
| Reviewer Name: | Jake LeJeune | Date Received: | 4/29/2020 |
| Disposition: | Declined | Date Completed: | 5/6/2020 |

Status Statement

Note: New temporary location for Burdell's

Review Comments:

1. Please provide a life safety plan that shows the travel distance from restroom 1417D in accordance with 36.2.4 and 36.2.6 of the 2018 edition of NFPA 101; also please provide fire extinguisher locations in accordance with 36.3.5.3 of the 2018 edition of NFPA 101.
2. Please provide the classification of hazard of contents in accordance with 36.1.5 of the 2018 edition of NFPA 101.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System

