

Plan Review Summary

Building Information

Project Name:	CODA Backfill-EXCEL Relocation Phase 1	Floor/Room #:	1st Floor
Building #:	155 & 155 B	Department:	CPSM
Occupancy Type:	Business	Budget:	\$900K
Construction Type:	IB	Type of Review:	Construction

Project Management

Project Manager:	Carla Barbour
Architect/Engineer of Record:	Kara Thomas-ASD-SKY
Construction Manager:	Carla Barbour
Aim Project Number:	0334-2020

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	5/6/2020
Disposition:	Declined	Date Completed:	5/11/2020

Status Statement

Note: MEP work; New lighting and audio/visual devices

Review Comments:

1. Sheet 1E2.01: please add an exit sign above door 124 so the open office area 124 will have a second means of egress in accordance with the 2018 edition of NFPA 101 chapter 7.10.1.5.1.
2. Sheet 1FA1.01: please add smoke detectors in the electrical and custodial closets to be in compliance with the GT Yellowbook Standard.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm