
Plan Review Summary

Building Information

Project Name:	Dr. Karen Feigh Research Lab	Floor/Room #:	2nd Floor
Building #:	101	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$230,000.00
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Mitchell Shelton
Architect/Engineer of Record:	Maria Del Mar Ceballos
Construction Manager:	
Aim Project Number:	0084-202

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	5/13/2020
Disposition:	Approved w/ Additional Requirements	Date Completed:	5/19/2020

Status Statement

Note: Adding Fire Alarm Devices; Strobes and horn/strobes

Review Comments:

1. As per ADAAG 4.1.1 and 4.28.3 (4), please change all strobes and horn/strobes to 75 candela output.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm
-